

POOL

Public Swimming Pool Daily Record Sheet



Marion County
OREGON
Health & Human Services

Month / Year	Name of Pool:	Location – City
Disinfectant Type:	Unstabilized	Stabilized
	<input type="checkbox"/> Sodium/Calcium Hypochlorite <input type="checkbox"/> Chlorine Generation <input type="checkbox"/> Bromine <input type="checkbox"/> Chlorine Gas <input type="checkbox"/> Other:	(contains Cyanuric Acid) <input type="checkbox"/> Trichlor <input type="checkbox"/> Dichlor
Required Testing Frequency:	Indoor: Every 4 hours	Outdoor: Every hour
	Indoor & Outdoor: Every 4 hours	

Operator's Initials	DATE	Daily Pre-Opening Tests					Total Alkalinity (1x / week)	Calcium Hardness (1x / wk)	Cyanuric Acid (1 x month)	TDS (Monthly)	Free Cl / Br Readings (1 or 4 hrs)				Number of Bathers - Total	Backwashed – Clean Filters	Recirculation Rate - GPM	Comments – Chemical Added / Amount Pool Problems Mechanical Breakdowns Equipment Replacement Swimmer Emergencies > (File Accident Report)
		Clarity (Yes/No)	Pool Temp (°F)	Free Chlorine/Bromine	Combined Cl	pH					Insert the Time the Test is Done (below)							
	1																	
	2																	
	3																	
	4																	
	5																	
	6																	
	7																	
	8																	
	9																	
	10																	
	11																	
	12																	
	13																	
	14																	
	15																	
	16																	
	17																	
	18																	
	19																	
	20																	
	21																	
	22																	
	23																	
	24																	
	25																	
	26																	
	27																	
	28																	
	29																	
	30																	
	31																	

Comments: _____

Swimming Pool Water Quality Parameters

	Min.	Ideal	Max.
Free Chlorine	0.8 ppm	1.5 - 3.0 ppm	5.0 ppm
Combined Chlorine	0	0	0.5 ppm
Bromine	3.0 ppm	3.0 - 5.0 ppm	8.0 ppm
pH	7.2	7.4 - 7.6	7.6
Total Alkalinity	80 ppm	100 - 125 ppm	200 ppm
Calcium Hardness	175 ppm	250 - 350 ppm	-
Cyanuric Acid	0	30 ppm (outdoor)	150 ppm