



**MARION COUNTY PUBLIC WORKS
BUILDING INSPECTION DIVISION**
5155 Silverton Rd NE PO Box 14500
Salem OR 97309-5036
(503) 588-5147 Fax (503) 588-7948
www.co.marion.or.us/PW/BuildingInspection

TABLE 1
OAR 340-71-0220
MINIMUM SETBACK REQUIREMENTS

Items Requiring Setback	From Subsurface Absorption Area Including Replacement Area	From Septic Tank and Other Treatment Units, Effluent Sewer and Distribution Units
1. Groundwater Supplies and Wells.	*100'	50'
2. Springs:		
• Upgradient.	50'	50'
• Downgradient.	100'	50'
**3. Surface Public Waters:		
• Year round.	100'	50'
• Seasonal.	50'	50'
4. Intermittent Streams:		
• Piped (watertight not less than 25' from any part of the on-site system).	20'	20'
• Unpiped.	50'	50'
5. Groundwater Interceptors:		
• On a slope of 3% or less.	20'	10'
• On a slope greater than 3%:		
• Upgradient.	10'	5'
• Downgradient.	50'	10'
6. Irrigation Canals:		
• Lined (watertight canal).	25'	25'
• Unlined:		
• Upgradient.	25'	25'
• Downgradient.	50'	50'
7. Cuts Manmade in Excess of 30 Inches (top of downslope cut):		
• Which Intersect Layers that Limit Effective Soil Depth Within 48 Inches of Surface.	50'	25'
• Which Do Not Intersect Layers that Limit Effective Soil Depth.	25'	10'
8. Escarpments:		
• Which Intersect Layers that Limit Effective Soil Depth.	50'	10'
• Which Do Not Intersect Layers that Limit Effective Soil Depth.	25'	10'
9. Property Lines.	10'	5'
10. Water Lines.	10'	10'
11. Foundation Lines of any Building, Including Garages and Out Buildings.	10'	5'
12. Underground Utilities.	10'	—

* 50-foot setback for wells constructed with special standards granted by WRD.

**This does not prevent stream crossings of pressure effluent sewers.