

## ELEVATION / FLOODPROOFING CERTIFICATION

INSTRUCTIONS: As a condition of approval for a Flood Plain Development Permit a certification of structure elevation or floodproofing may be required (Section 178.060 of the Marion County Zoning Ordinance). Section 1 of this form is for the purpose of certifying that a structure has been constructed so that the lowest floor is at an elevation of one (1) or more feet above the 100 year flood level. The certification must be completed by a registered land surveyor or civil engineer.

Section 2 is used to certify that a structure has been adequately floodproofed. It must be completed by a registered civil/structural engineer.

Please complete the applicable section and certification and return the completed form to the County Planning Department at 220 High Street NE, Salem, Oregon.

### SECTION 1

I certify that the structure located at (address) 11866 RIVER HAVEN LANE,  
MEHAMA is constructed so that the lowest floor  
is at an elevation of 586.00\* feet NGVD (mean sea level).  
\* SEE ATTACHED MEMO.

### SECTION 2

I certify that the structure located at (address) \_\_\_\_\_  
\_\_\_\_\_, together with the proposed utility and  
sanitary facilities, are designed so that the structure will be watertight to an  
elevation of \_\_\_\_\_ feet NGVD (mean sea level), with walls substantially  
impermeable to the passage of water and structural components having the compati-  
capability of resisting hydrostatic and hydrodynamic loads and effects of  
bouyancy.

My certification is conditional upon the actual construction of the building in  
strict accordance with the plans presented to me.

In the event of flooding, will this degree of floodproofing be achieved with  
human intervention? \_\_\_\_\_ (see Note)

Will the structure be occupied as a residence? \_\_\_\_\_

NOTE: Floodproofed with human intervention means that water will enter the  
structure when floods up to the base flood level occur, unless measures  
are taken prior to the flood to prevent entry of water (e.g., bolting  
metal shields over doors and windows).

Affix seal here:

Name Ronald D. Polvi  
(print or type)

Address Rte. 1 Box 180 Dayton, OR 97114

Signature Ronald D. Polvi

Case No. 83-18

Date June 16, 1983