

FP 81-10

INSTRUCTIONS: As a condition of approval for a Flood Plain Development Permit a certification of structure elevation or floodproofing may be required (Section 178.060 of the Marion County Zoning Ordinance). Section 1 of this form is for the purpose of certifying that a structure has been constructed so that the lowest floor is at an elevation of one (1) or more feet above the 100 year flood level. The certification must be completed by a licensed land surveyor, registered engineer or architect.

Section 2 is used to certify that a structure has been adequately floodproofed. It must be completed by either a registered professional engineer or architect.

Please complete the applicable section and certification and return the completed form to the County Planning Department at 220 High Street NE, Salem, OR.

SECTION 1
For Dwayne and Bethal
Edward Wolf

I certify that the structure located at (address) 4861 Delancy Rd

Turner OR is constructed so that the lowest floor (mobile home) is at an elevation of 277 1/2 feet NGVD (mean sea level).
100 yr flood = 275'

SECTION 2

I certify that the structure located at (address) _____

_____, together with the proposed utility and sanitary facilities, are designed so that the structure will be watertight to an elevation of _____ feet NGVD (mean sea level), with walls substantially impermeable to the passage of water and structural components having the capability of resisting hydrostatic and hydrodynamic loads and effects of bouyancy.

My certification is conditional upon the actual construction of the building in strict accordance with the plans presented to me.

In the event of flooding, will this degree of floodproofing be achieved with human intervention**? _____

Will the structure be occupied as a residence? _____

**Floodproofed with human intervention means that water will enter the structure when floods up to the base flood level occur, unless measures are taken prior to the flood to prevent entry of water (e.g., bolting metal shields over doors and windows).

Signature William J. Lulay
Address 1035 13th St SE Salem OR 97302
Date April 13, 1982
(CASE NO. FP 81-10)

Affix Seal Here:
REGISTERED PROFESSIONAL LAND SURVEYOR
William J. Lulay
OREGON
JULY 13, 1978
WILLIAM J. LULAY
1827